



NH-18 LONG SWEEP CLEARANCE REQUIREMENTS

NOTE:
 RESTRAINT IS REQUIRED ON ALL PIPE 5" AND LARGER AT ALL BRANCH TAKE-OFFS, AND CHANGES IN DIRECTION TO PROTECT AGAINST HORIZONTAL MOVEMENT AND JOINT SEPARATION

06/02/20

NOTICE: THE INFORMATION ON THIS PAGE PROVIDES GENERAL GUIDELINES. IT SHOULD BE USED ONLY AS A REFERENCE AND NOT AS A GAURANTEE OF PERFORMANCE. SPECIFIC INSTALLATION INSTRUCTIONS AND TECHNIQUES MAY BE REQUIRED AS A RESULT OF LOCAL PLUMBING AND BUILDING CODES, ENGINEERING SPECIFICATIONS AND INSTRUCTIONS.

CPF-22

START OF ELEVATION
 USING NH-18
 LONG SWEEP

CHARLOTTE
 PIPE AND FOUNDRY COMPANY